

PLANNING DEPARTMENT

Appeals Received from 25 Sep 2023 to 29 Sep 2023

Planning No	Application Type	Application Date	Decision Date	Local Auth. Decision	Appeal Lodged Date
20221633	Permission	09 Dec 2022	31 Aug 2023	Granted subject to conditions	26 Sep 2023
Applicant :	The Electricity Supply Board (ESB)				
Location :	Great Island, Kilmokea				
Proposal :	<p>Permission for the development of a new 38kV electricity circuit between the existing Knockmullen ESB Substation, New Ross and the existing Great Island ESB Substation, within the Great Island generation station complex. The circuit - which traverses the townland of Great Island, Creakan Lower, Creakan Upper, Butlersland, Ballydock, Priesthaggard, Poulmaloe, Whitechurch, Dunganstown, Killowen, Oldcourt, Stokestown, Landscape, Camlin and Knockmullin, County Wexford, will be c.13.75 km in length and will consist of c.12 km of overhead line (OHL) and c.1.75 km of underground cable (UGC). The OHL structures (87 No.) will consist of single and double wood polesets, with a height above ground level ranging from c.9.7 m to c. 18 m and will require below ground foundations and staywires at specific locations. The UGC will primarily run along public roads and will consist of electrical cables laid in underground ducts buried in a trench (with varying dimensions between c.0.6 m and c.0.9 m width and a depth of c.1.2 m). For information: the proposed OHL passes through the curtilage associated with the demesne lands of 'Landscape House' which is a protected Structure in the Wexford County Development Plan 2022-2028 (RSP Ref: WCC0530). Permission is sought for all associated works including temporary works such as the creation of access ways etc. Planning permission is sought for a ten (10) year period. A Natura Impact Statment (NIS) has been prepared and will be submitted to the planning authority with the application.</p>				

Total No. of Appeals Received for Period :1